Power Supply

TR989361

START FROM HERE

- Make sure **POWER** is **COMPLETELY OFF** at the fuse box
- Have your fixture installed by a qualified licensed electrician
- Prepare everything in a clear area
- · Wear gloves at all time during this installation
- · Read instructions carefully before you start assembly
- · Keep this installation sheet for future reference

Technical Support: 1-855-855-8926

2a.

TRT989100/TRT989200


(Sold Separately)

Please Note:

- To be used with max track length of 20m
- Use ELV (Electronic Low Voltage) or TRIAC type of dimmer for dimming application
- 120V input

POWERING THE TRILO TRACK SYSTEM

Single Power Supply



- 2. Separate mounting plate (1c) from canopy cover (3a) by removing screws (3b)
- Make proper electrical connections between LED and DC driver, LED- Negative, LED+ Positive using wire nuts (1b) provided
- Make proper electrical connections between driver (4a) and power block (4b) (black to hot "L", white to neutral "N", green to "GND") with wire nuts (1b) provided in hardware package and place driver (4a) in electrical junction box (1a)
- **5.** Attach mounting plate **(1c)** to electrical junction box **(1a)** using junction box screws provided **(1d)** in hardware package
- **6.** Attach power block **(4b)** to track **(2a)**
- **1.** Attach canopy cover (3a) to end of track TRT989100/TRT989200 (2a) (Sold Separately) and secure to mounting plate (1c) with screws (3b)





1d.

1b.

4b.

3b.





Note: If using multiple power supplies, isolation connector TRC989971 **(5b) (Sold Separately)** must be used

1. Attach isolation connector (5b) (Sold Separately) to track (2a) and secure to mounting surface with screw (5c) and anchor (5a)

Wires	
Hot (Black)	
Neutral (White)	
Ground (Green)	